

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF CARROLL COUNTY WATER)	
DISTRICT NO. 1 FOR A DEVIATION FROM)	
THE REQUIREMENTS OF 807 KAR 5:066,)	CASE NO. 91-091
SECTION 5(4) REGARDING WATER STORAGE)	

O R D E R


By application received March 18, 1991, Carroll County Water District No. 1 ("Carroll Water") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Carroll Water states in its application that its average daily water usage, including unaccounted-for water, is approximately 392,688 gallons, and that its current water storage capacity is 480,000 gallons.


The Commission, having reviewed the application and being otherwise sufficiently advised, finds that Carroll Water is in compliance with the requirements of Commission Regulation 807 KAR 5:066, Section 5(4), and as such no deviation is required.

IT IS THEREFORE ORDERED that Carroll Water is in compliance with the requirements of 807 KAR 5:066, Section 5(4), and as such no deviation is required. Carroll Water's application is hereby dismissed.

Done at Frankfort, Kentucky, this 4th day of April, 1991.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director